

205 NORTH LIMESTONE STREET  
GAFFNEY, SOUTH CAROLINA 29340



TELEPHONE: 864-487-8516  
CHIEF: 864-487-8517  
FAX: 864-489-2511

POST OFFICE BOX 2109  
GAFFNEY, SOUTH CAROLINA 29342

**JAMES V. CAGGIANO, JR.**  
*FIRE CHIEF*

## Food Truck Safety Checklist

All Mobile Food Preparation Vehicles shall obtain a City Business License and Food Truck Permit from the City of Gaffney Finance Department. All vehicles that are equipped with appliances that produce smoke or grease-laden vapors are subject to a fire inspection in accordance with IFC 319.

<b><u>Safety Standards in Addition to Annual Fire Inspection</u></b>	<b><u>Yes</u></b>	<b><u>No</u></b>
Minimum separation distance of 10 feet between front and rear bumpers of vehicle and other vehicles or buildings.		
All vehicles must have a 2A:10BC (5lb) ABC extinguisher installed.		
In addition, a Type K extinguisher shall be installed in vehicles with grills, stoves, and deep fryers that produce grease laden vapors.		
Cooking oil storage shall not exceed 200 gallons and shall be secured for transport.		
Electrical connections must be made using permanent wiring. Extension cords shall not replace permanent wiring and shall not pass through walls, ceilings, or floors.		
Generators shall only be fueled at motor vehicle fueling stations. At no times should gas cans be stored on or near the food truck.		
No LP tanks shall be installed, transported, or stored inside the vehicle or on the roof at any time. Maximum capacity 200 pounds.		
No CNG tanks shall be installed, transported, or stored inside the vehicle or on the roof at any time. Maximum capacity 1300 pounds.		
Vehicles with a grill, stove, or deep fryer within the vehicle shall have a type 1 hood system in place above appliances that produce grease laden vapors.		
Hood and exhaust systems shall be inspected in compliance with IFC section 607		
Vehicles equipped with LP gas equipment shall have an LP gas alarm. Vehicles equipped with CNG equipment shall have a methane alarm.		